WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32014
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12768

1. OWNER Dan Barnard
MAILING ADDRESS 3180 Pershing Ln Carson City NV 89705
ADDRESS AT WELL LOCATION Magpie Way New Washoe City, Carson City, NV

2. LOCATION NW ¼ NW ¼ Sec. 5 T. 16 N/S R. 20 E. Washoe County
PERMIT NO. ~~City 3567~~ Issued by Water Resources | 050-412-02 Parcel No. | Washoe City #5 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ blow sand, soft		0	7	7
Cemented pea gravels w/ thin sand lens, Hard to Medium Hard		7	83	76
Pea gravel w/ sand	–	83	110	27
T.D. 110 ft				

Date started July 26, 1989
Date completed July 27, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed & gravel packed with 250-450 air Blew for 3 hours to clean, 16-18 GPM			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 to 60 inches Total depth 110 feet
9 1/8 inches
..... inches
Casing record 6 5/8 O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	110 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 90 feet to 110 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 48 feet below land surface
Flow 16-18 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & H Pump Co Contractor
Address Carson City, NV 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] By driller performing actual drilling on site or contractor
Date July 28, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627