

OFFICE USE ONLY
 Log No. 32100
 Permit No. _____
 Basin 4-49

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 12195

PRINT OR TYPE ONLY

1. OWNER Britt BLAKEMAN ADDRESS AT WELL LOCATION SAME
 MAILING ADDRESS 160 KITTLEDGE CANYON TR BLK 10 Lot 1
ELKO, NV 89801

2. LOCATION NE 1/4 SW 1/4 Sec 33 T. 35 N/S R. 65 E ELKO County _____
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		0	18'	
SAND		18'	25'	
Hard SAND STONE		25'	84'	
Light TAN CLAY		84'	110'	
Hard Rock		110'	120'	
Coars SAND CLAY		120'	250'	
SOFT SAND Gravel	Water	250'	255'	5'
Coars SAND CLAY		250'	300'	

8. WELL CONSTRUCTION

Diameter 6" inches Total depth 300 feet
10" Hole inches
 inches

Casing record 6" STEEL
 Weight per foot _____ Thickness 165 LB/WT

Diameter	From	To
<u>6"</u> inches	<u>1 1/2</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 5' feet
 Gravel packed: Yes No
 Gravel packed from 5' feet to 300 feet

Perforations:
 Type perforation Slots
 Size perforation 3/16 - 3"
 From 240' feet to 260' feet
 From 280' feet to 300' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

STATE ENGINEERS OFFICE
 RECEIVED
 Date started 5-10 1989
 Date completed 6-25 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 26' feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 60th °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AAA Drilling Co Contractor
 Address 357 West River ST ELKO Contractor

Nevada contractor's license number issued by the State Contractor's Board 20684
 Nevada contractor's driller's number issued by the Division of Water Resources 904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shel C. Fungo
 By driller performing actual drilling on site or contractor
 Date 6-30-89

BAILER TEST

G.P.M. 32 gpm Air Test Draw down 45 feet 3 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours