WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32137
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12453 "B"

1. OWNER Jack Gardner
MAILING ADDRESS Box 1700 Zephyr Cove, Nevada
ADDRESS AT WELL LOCATION Parcel (40 acre) Gardnerville, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 25 T. 12 N/S R. 19 E. Douglas County
PERMIT NO. ____ Issued by Water Resources | 19-300-21 Parcel No. | Day Canyon Estates Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Hard

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden - Sandy - Clay		0	12	12
D.G. with Boulders & Clay Streaks and Sand w/ iron pyrite		12	120	108
TD 120 ft				
Note: left 6 ft pea gravel in bottom to stop sand & pyrite from entering casing				

Date started Sept 5, 1989
Date completed Sept 7, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clear Water to remove mud & gravel pack Developed with air Blew 20-22 GPM from 95'			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 12¼" to 50' inches Total depth 120 feet
9⅞ inches
____ inches
Casing record 6⅝" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6⅝ inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 100 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 5 feet below land surface
Flow 20-22 G.P.M. ____ P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AE H Pump Co (Contractor)
Address Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald Phinnell
By driller performing actual drilling on site or contractor
Date 9/8/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627