WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32148
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10791

1. OWNER Bently Nevada Corporation
MAILING ADDRESS 1617 Water Street, Minden, Nevada 89423
ADDRESS AT WELL LOCATION Northeast Minden - Johnson Lane Area

2. LOCATION SW ¼ NW ¼ Sec. 6 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. 50651 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. MW19B PROPOSED USE Monitor
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay, gravel		0	5	
sands		5	35	
imbedded clay, sand, & gravel		35	69	
gray clay silt		69	85	
yellow clay		85	87	
small to large gravels		87	108	
sans & gravels		108	124	
clay		124	125	

'89 SEP 19 AM 10:08 STATE

Date started July 17, 19 89
Date completed August 26, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 9-7/8 inches Total depth 125 feet
..... inches
..... inches
Casing record 6-5/8 inch O.D. x 1/4 mild steel
Weight per foot 17.02 Thickness

Diameter	From	To
6 inches	+1 feet	125 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type neat cement
Depth of seal 101 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 103 feet to 125 feet

Perforations:
Type perforation 6 inch stainless steel screen
Size perforation .035 inch
From ..... feet to ..... feet
From 105 feet to 135 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 8 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 N. Virginia St., Reno, Nevada (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540
Signed [signature] (By driller performing actual drilling on site or contractor)
Date September 12, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627