

OFFICE USE ONLY
 Log No. **32175T**
 Permit No. _____
 Basin **6-83**

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. **13028**

1. OWNER Richard Junta ADDRESS AT WELL LOCATION 370 Panamint Rd # 37
 MAILING ADDRESS 370 Panamint Rd # 15
Reno, Nv 89511

2. LOCATION SW 1/4 NE 1/4 Sec 6 T 17 N/S R 21 E Storey County
 PERMIT NO. 03-431-18 Virginia City Highlands Unit # 2
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D. G. and brown clay		0	76	76
Heavy blue grey clay with solids - traces 1/8 inch		76	155	79
Blue grey sandstone	X	155	220	65
T.D. 220 ft				

8. 10" -50' WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 220 feet
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+ 1	220

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 220 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 195 feet to 215 feet
 From _____ feet to _____ feet

Date started 8/23/89, 19____
 Date completed 8/25/89, 19____

7. WELL TEST DATA

Pump RPM	Flow	Pressure	After Hours Pump
<u>110</u>	<u>20+ GPM</u>	<u>110 PSI</u>	<u>to clean</u>
	<u>- approximately 20+ GPM</u>		

9. 150' WATER LEVEL
 Static water level 150 feet below land surface
 Flow 20+ G.P.M. P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L Sparks, NV 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1037
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 8/28/89

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours