



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 9683

PRINT OR TYPE ONLY

1. OWNER Ernest Tuller ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 2290 Cougar St. same as mailing  
Silver Springs, NV 89429  
 2. LOCATION SE 1/4 SW 1/4 Sec. 20 T. 17N N/S R. 25 E. Lyon County  
 PERMIT NO. Issued by Water Resources 17-464-04 Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand		0	15	15
sand & brown clay		15	18	3
sand		18	20	2
brown clay		20	25	5
brown clay & sand		25	36	11
coarse sand		36	105	69
brown clay & coarse sand		105	150	45
coarse sand		150	180	30
brown clay & coarse sand		180	195	15
coarse sand		195	198	3
brown clay & coarse sand		198	200	2
coarse sand & gravel	X	200	224	24

8. WELL CONSTRUCTION

Diameter 12 5/8 inches Total depth 225 feet

Casing record.....  
 Weight per foot..... Thickness 188

Diameter	From	To
<u>8 5/8</u> inches	<u>(+) 1</u> feet	<u>224</u> feet
.....inches	.....feet	.....feet

Surface seal: Yes  No  Type grout  
 Depth of seal..... 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from..... 50 feet to..... 224 feet

Perforations:  
 Type perforation..... sawed  
 Size perforation..... 3/32" x 3" x 16 rows  
 From..... 204 feet to..... 224 feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

9. WATER LEVEL

Static water level 39 feet below land surface  
 Flow..... G.P.M. P.S.I.  
 Water temperature..... cold °F Quality..... good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros. Drilling Contractor  
 Address 162 N. Bybee Ln. Yerington, NV Contractor 89447  
 Nevada contractor's license number issued by the State Contractor's Board..... 15646  
 Nevada contractor's driller's number issued by the Division of Water Resources..... 870 & 640  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller..... 870  
 Signed Bill Ogden By driller performing actual drilling on site or contractor  
 Date 9/7/89

Date started..... 8-25 1989  
 Date completed..... 8-30 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>N/A</u>	<u>15.0</u>	<u>52</u>	<u>68</u>
.....	.....	.....	.....
.....	.....	.....	.....
.....	.....	.....	.....

BAILER TEST

G.P.M. 20 Draw down 3 feet 1 1/2 hours  
 G.P.M. Draw down..... feet..... hours  
 G.P.M. Draw down..... feet..... hours