

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 13024

PRINT OR TYPE ONLY

1. OWNER Norm Cloutier ADDRESS AT WELL LOCATION 435 Cloutier  
 MAILING ADDRESS 425 Cloutier  
Sun Valley, Nv 89433

2. LOCATION SE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 13 T. 20 N/S R. 19 E Washoe County  
 PERMIT NO. 88-220-02 - Sun Valley Subdivision Name  
Issued by Water Resources Parcel No.

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red clay		0	20	20
Gray clay [Sticky]		21	36	15
Decomposed granite purple, white, & brown [soft]		36	57	21
D.G. [highly fractured] granite blue gray		57	67	10
Granite blue gray semi decomposed		67	84	17
Granite Blue Gray highly fractured	X	84	100	16
T.D. 100 ft				

8.10" -55' WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 100 feet

Casing record 6 5/8 inch

Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>100</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout

Depth of seal 55 feet

Gravel packed: Yes  No

Gravel packed from 55 feet to 100 feet

Perforations:

Type perforation factory

Size perforation 3/32 X 3 double

From 80 feet to 100 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 8/7/89, 19\_\_\_\_  
 Date completed 8/8/89, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 56 feet below land surface

Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.

Address 625 Spice Islands Dr Suite L Sparks, Nv 89431

Nevada contractor's license number issued by the State Contractor's Board 15291

Nevada contractor's driller's number issued by the Division of Water Resources 1132

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509

Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor

Date 8/8/89