WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32216
Permit No.
Basin 7-92a

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13023

1. OWNER Byron Wholey
MAILING ADDRESS 3210 Suncloud Cr
Reno, Nv 89506

ADDRESS AT WELL LOCATION 10190 Crockett dr

2. LOCATION SE ¼ NW ¼ Sec. 25 T. 21 N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 086-171-06 (Parcel No.) — Silver KNolls Ranch Estates # 3 (Subdivision Name)

3. TYPE OF WORK
New Well [XX] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [XX] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty brown clay		0	5	5
Coarse green yellow and white D.G. sands		5	14	9
Green & tan clay		14	55	41
Coarse D.G. green yellow & white		55	60	5
Tan clay traces of D.G sands		60	108	48
Coarse tan yellow white D.G. & small clay zones		108	127	19
Sticky tan clay		127	136	9
Coarse D.G. sand		136	149	13
Sticky tan clay		149	168	19
Coarse tan yellow white sands		168	210	42
Sticky tan clay		210	222	12
T.D. 222 ft				

Date started 8/24/89, 19
Date completed 8/25/89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

SEP 12 A10:30

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 222 feet
inches
inches
Casing record 6 5/8 inch
Weight per foot 10.78 Thickness .156

Diameter	From	To
6 5/8 inches	+1 feet	222 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type Neat cement
Depth of seal 54 feet
Gravel packed: Yes XX No [ ]
Gravel packed from 54 feet to 222 feet

Perforations:
Type perforation Johnson screen
Size perforation .030
From 192 feet to 212 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 105 feet below land surface
Flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc. (Contractor)
Address 625 Spice Islands Dr Suite L Sparks, Nv 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources (the on-site driller) 1511
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 8/30/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627