

OFFICE USE ONLY
 Log No. 32248
 Permit No. 2-42
 Basin

8412

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8412

1. OWNER JANE Zimmerman + Gary Noeske ADDRESS AT WELL LOCATION SAME
 MAILING ADDRESS ELKO NV 89801

2. LOCATION NE 1/4 NE 1/4 Sec. 29 T. 35 N/S R. 56 E ELKO County

PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
200m		0	3'	
SAND		3'	8'	
SAND Gravel	water	8'	43'	
Blue CLAY		43'	64'	
Gravel Cemented		64'	76'	12'
Blue CLAY		76'	100'	

8. WELL CONSTRUCTION

Diameter 6" inches Total depth 100' feet
10" Hole inches
 inches
 Casing record 6" STEEL
 Weight per foot Thickness 156

Diameter	From	To
<u>6"</u> inches	<u>1</u> feet	<u>100'</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type Cement
 Depth of seal 350' feet
 Gravel packed: Yes No
 Gravel packed 350' feet to 100' feet

Perforations:
 Type perforation slots
 Size perforation 3/16" - 3
 From 43' feet to 83' feet
 From 93' feet to 100' feet
 From feet to feet
 From feet to feet
 From feet to feet

9. WATER LEVEL

Static water level 16' feet below land surface
 Flow G.P.M. P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Co Contractor
 Address 357 West River St Elko Contractor
 Nevada contractor's license number issued by the State Contractor's Board 20684
 Nevada contractor's driller's number issued by the Division of Water Resources 904
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
 Signed Shou C. Wang
 By driller performing actual drilling on site or contractor
 Date 8-18-89

Date started 8-14-89 STATE ENGINEERS-1111, 1989
 Date completed 8-14-89, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>20</u>	<u>45</u>	<u>27</u>	<u>5</u>

BAILER TEST
 G.P.M. 45 Air Draw down 27 feet 5 hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours