WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32365
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4068

1. OWNER ARCO Petroleum Products Company
MAILING ADDRESS 1055 West Seventh Street
P.O. Box 2570 Los Angeles, CA 90051-0570

ADDRESS AT WELL LOCATION W13-2

2. LOCATION N.E. ¼ N.W. ¼ Sec. 10 T. 21 S. N/S R. 61 E. Clark County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒ monitor
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravelly sand | | 0 | 2' | 2' |
| Silty sand / Silty Clay | | 2' | 25' | 23' |

RECEIVED
JUN 19 1989
Div. of Water Resources
Branch Office Las Vegas, NV

Date started 9-21, 19 88
Date completed 9-21, 19 88

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 25 feet
inches
inches
Casing record Surface to 25'
Weight per foot ..... Thickness Sch. 40 PVC

| Diameter | From | To |
|---|---|---|
| 4 inches | Surface feet | 25 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Neat cement
Depth of seal 2' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 2' feet to 25' feet

Perforations:
Type perforation Factory Slotted Screen
Size perforation .020 inch
From 5 feet to 25 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 10.2 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson / Converse Consultants (Contractor)
Address 4670 South Polaris Avenue, Las Vegas NV, 89103-5615 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589
Signed Donald J. Wilson
By driller performing actual drilling on site or contractor
Date 6-9-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627