

OFFICE USE ONLY  
 Log No. 32399  
 Permit No. \_\_\_\_\_  
 Basin. 8-105

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10376

1. OWNER John & Terri Byres ADDRESS AT WELL LOCATION 1056 TyBo ct.  
 MAILING ADDRESS P.O. Box 988 Minden NV 89423

2. LOCATION NW 1/4 SR 12 T 12 N 20 E Douglas County  
 PERMIT NO. 23-232-10 PINE NUT major 182  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>clay with extra Bedded gravel &amp; cobbles</u>		<u>0</u>	<u>190</u>	<u>190</u>
<u>Cobbles gravel concrete</u>	<u>X</u>	<u>190</u>	<u>260</u>	<u>70</u>

'89 OCT 25 09:52 RECEIVED STATE ENGINEERS OFFICE

Date started 10-19-89  
 Date completed 10-23-89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>AIR Lift</u>	<u>15-20</u>	<u>6pm</u>	<u>from</u>
<u>220'</u>	<u>for 3 hrs</u>		

BAILER TEST

G.P.M. None Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 260' feet

Casing record  
 Weight per foot 10lb Thickness .156

Diameter	From	To
<u>6</u> inches	<u>+2</u> feet	<u>260'</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 260' feet

Perforations:  
 Type perforation mill cuts  
 Size perforation 3/8 x 2 1/2  
 From 220 feet to 260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 156 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality OK

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DASIS DRILLING INC. Contractor  
 Address P.O. Box 21421 CARSON CITY NV. Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0023129  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386  
 Signed T. L. Amzalom By driller performing actual drilling on site or contractor  
 Date 10-23-89