WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32421
Permit No.
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO 10859

1. OWNER Dr Charles Clemmensen
MAILING ADDRESS 124 E Ketin Carson City, NV
ADDRESS AT WELL LOCATION Parcel #1 Kings Canyon Carson City, NV

2. LOCATION NW ¼ NE ¼ Sec. 23 T. 15 N/S R. 19 E Carson City County
PERMIT NO. Issued by Water Resources | 07-072-14 Parcel No. | None Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	12	12
Alluvial fill w/ Clay		12	160	148
Clay, tight		160	175	15
Boulders Cemented with clay		175	185	10
Alluvial, clay mixed, hard		185	215	30
Cemented alluvial fill, hard		215	250	35
Grey granite, fractured, w/ green olivine		250	280	30
T.D. 280 Ft				
See pg. 2 for pump test.				

Date started Oct 6, 1959
Date completed Oct 16, 1959

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed cold air. Blew 30" GPM from 250		250-450	

STATE ENGINEERS OFFICE
'89 OCT 24 A9:56

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole ..... inches Total depth 280 feet
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	280 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Pedi Mix
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 280 feet

Perforations:
Type perforation Factory mill slot
Size perforation 3/32" x 3"
From 240 feet to 280 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 102 feet below land surface
Flow 30 G.P.M. ..... P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address Carson City, NV 89701
Contractor
Nevada contractor's license number 23495
Nevada contractor's drillers number
Nevada driller's license number 1535
Actual Driller
Signed [signature]
Contractor
Date Oct 16, 1959

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

Log # 32421
N15E1923AB

A & H PUMP CO.
5551 Hwy. 50 East #3
Carson City, Nevada 8970
883-0459 - 883-402
885-1889

Oct 19, 1989

Dr Charles Clemmensen
120 E John
Carson City, Nv

Well test, domestic well on Parcel 1, Kings Canyon Area
Size test pump: 2HP 19GPM, Set on 1¼" pipe to a depth of 210 feet.
Static level in well @ start of test: 104 feet

Start test @ 1:45 PM	— 104 ft				
1:48	— 112 ft				
1:50	— 116 ft				
2:00	— 125 ft				
2:15	— 132 ft	— 24 GPM	@	55 PSIG	
2:25	— 137 ft	— "	"	"	
2:30	— 139 ft	— "	"	"	
2:40	— 142 ft	— 23	"	"	
2:50	— 144 ft	— "	"	"	
3:00	— 146 ft	— "	"	"	
3:10	— 147 ft	— "	"	"	
3:20	— 151 ft	— 24	"	50 PSIG	
3:30	— 151 ft	— 24	"	"	
3:45	— 151 ft	— "	"	"	
4:00	— 151 ft	— "	"	"	

End of draw-down test at 4:00. well pumping level stabilized at 151 ft pumping 24 GPM with 50 PSI on pressure gauge.

Albert Eddy