WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 32463
Permit No.
Basin 4-L19

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 9025

1. OWNER Allyn Boyiac
MAILING ADDRESS Box 2064, Elko, Nevada 89801

ADDRESS AT WELL LOCATION
½ North Raley's N. SAGECREST DR.

2. LOCATION ~~S½~~ SE ¼ ~~S½~~ SW ¼ Sec. 8 T. 34 N/S R. 55 E Elko County
PERMIT NO. ~~File 280346~~ (Issued by Water Resources) | Parcel No. #3 APN-0609C-066 | Subdivision Name Clover Hills 280346

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| tan clay, sand & gravel | | 0 | 95 | 95 |
| cemented course sand & gravel | | 95 | 170 | 75 |
| tan clay & sand & gravel layers | | 170 | 210 | 40 |
| 80% white clay 20% sand | | 210 | 370 | 160 |
| 20% white clay 80% sandstone | | 370 | 390 | 20 |
| white clay & sand | | 390 | 475 | 85 |
| medium to course sand | | 475 | 540 | 65 |
| clay & sand | | 540 | 545 | 5 |

Date started October 3, 19 89
Date completed October 7, 19 89

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8-5/8 inches Total depth 545 feet
..... inches
..... inches
Casing record 8-5/8 x .250 wall
Weight per foot 18.18 Thickness

| Diameter | From | To |
|---|---|---|
| 8-5/8 inches | +1 feet | 545 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 545 feet

Perforations:
Type perforation single perforation
Size perforation 3/32 x 3
From 240 feet to 540 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 260 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sargent Irrigation Company (Contractor)
Address P.O. Box 2646, Elko, Nv 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1493
Signed [signature] (By driller performing actual drilling on site or contractor)
Date October 10, 1989

STATE ENGINEERS OFFICE
OCT 12 AM 10:41 '89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627