

#2

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO.12108

PRINT OR TYPE ONLY

1. OWNER City of Wendover ADDRESS AT WELL LOCATION Goshute Valley
 MAILING ADDRESS c/o Elko County Courthouse West Wendover
Elko, NV 89801

2. LOCATION SW 1/4 NW 1/4 Sec 5 T 35 N/S R 67 E Elko County
 PERMIT NO. Waiver MW Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------------------|--------------|------|-----|------------|
| Sand & gravel w/s silty clay | | 0 | 5 | 5 |
| Silty clay | | 5 | 8 | 3 |
| Silty clay w/s cobbles | | 8 | 12 | 4 |
| Silty clay | | 12 | 22 | 10 |
| Course sand & gravel w/s 50% clay | | 22 | 50 | 28 |
| 90% clay w/s course sand | | 50 | 75 | 25 |
| Silstone w/s clay | | 75 | 78 | 3 |
| 96% clay w/s sand | | 78 | 105 | 28 |
| Course sand & gravel w/s 50% clay | | 105 | 135 | 30 |
| Cemented gravel w/s 50% clay | | 135 | 142 | 7 |
| Course sand & gravel w/s 50% clay | | 142 | 224 | 82 |
| Cemented gravel | | 224 | 226 | 2 |
| 70% clay w/s sand & gravel | | 226 | 235 | 9 |
| Cemented gravel (hard) | | 235 | 241 | 6 |
| 90% clay w/s sand | | 241 | 278 | 37 |
| Cemented gravel | | 278 | 280 | 2 |
| 90% clay w/s sand | | 280 | 337 | 57 |

8. WELL CONSTRUCTION
 Diameter 8 inches Total depth 337 feet
 Casing record 2" PVC
 Weight per foot _____ Thickness Schedule 80

| Diameter | From | To |
|--------------------|------|-----|
| 8" Steel Conductor | 0 | 20 |
| 2" PVC Blank | 0 | 137 |
| 2" PVC Perf | 137 | 337 |

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 337 feet
 Perforations:
 Type perforation .020 slot
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From See Above feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 9-27, 1989
 Date completed 10-05, 1989

7. WELL TEST DATA

| Pump RPM | Flow (GPM) | Drawdown (ft) | Water Hours Pump |
|----------|------------|---------------|------------------|
| | | | |
| | | | |
| | | | |
| | | | |

9. WATER LEVEL
 Static water level 43.5 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc.
 Address P.O. Box 592 Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada contractor's driller's number issued by the Division of Water Resources C-23
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 10-13-89

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours