WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32479
Permit No.
Basin 4-70

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12904

1. OWNER City of Winnemucca
MAILING ADDRESS Humboldt Co. Courthouse
Winnumucca, NV. 89445

ADDRESS AT WELL LOCATION OW7 @ Sewer Treatment Facilities

2. LOCATION NW ¼ SW ¼ Sec. 25 T. 36 N/S R. 37 E. Humboldt County

PERMIT NO. M/O-196 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Silty SAND | | 0 | 10 | 10 |
| SAND w/ Gravels | | 10 | 25 | 15 |

'89 NOV -3 A10:25
STATE ENGINEER

Date started October 25, 1989
Date completed " ", 19 "

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 2 inches Total depth 25 feet
..... inches
..... inches
Casing record 2" PVC
Weight per foot ..... Thickness Sch 40

| Diameter | From | To |
|---|---|---|
| 2" Blank inches | 0 feet | 9 feet |
| 2" Perf inches | 9 feet | 19 feet |
| 2" Blank inches | 19 feet | 24 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement & Concrete
Depth of seal 8 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 8 feet to 25 feet

Perforations:
Type perforation PVC Schedule 40 Slot
Size perforation 0.010
From 9 feet to 19 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 16 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name [illegible] Contractor
Address 1635 Bellford RD Reno Nev 89509 Contractor

Nevada contractor's license number issued by the State Contractor's Board .....

Nevada contractor's driller's number issued by the Division of Water Resources .....

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028

Signed [illegible] By driller performing actual drilling on site or contractor

Date 10/31/89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627