WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32531
Permit No. 51308
Basin 8-105 Carson V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 10801

1. OWNER GARDNERVILLE RANCHOS
MAILING ADDRESS c/o Lumos & Associates
800 E. Graves, Carson City, Nv. 89701

ADDRESS AT WELL LOCATION
GARDNERVILLE RANCHOS / Dresserville & Tomlin
Gardnervile, nv.

2. LOCATION SE ¼ SW ¼ Sec. 9 T. 12 N/S R. 20 E. Douglas County

PERMIT NO. 51308 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE GRID #6
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Coarse sand, gravel, and small boulders		3	40	37
Sand & gravel		40	429	389
Clay		429	434	5

'89 NOV 21 A10:14 RECEIVED STATE ENGINEERS OFFICE

Date started September 12 19 89
Date completed Ocotboer 20, 19 89

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 26 inches Total depth 434 feet
..... inches
..... inches
Casing record 18 inch x .375 inch wall
Weight per foot 70.59 Thickness .....

Diameter	From	To
18 inches	+1 feet	210 feet
inches	feet	feet
inches	430 feet	434 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement sand grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 434 feet
Chevreaux 1/8 icnh x 1/4 inch Quartz Pebbles

Perforations:
Type perforation Roscoe Moss 18 inch wire wrap screen
Size perforation .100 inch slot mild steel Heavy wieght
From ..... feet to ..... feet
From 210 feet to 430 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 45 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CHAS. SARGENT IRRIGAITON INC. (Contractor)
Address 9955 N. VIRGINIA ST., RENO, NV. 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1573
Signed Larry M. Gracton (By driller performing actual drilling on site or contractor)
Date 11-20-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627