WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32587
Permit No.
Basin 7-9020

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13725

1. OWNER GREG & BECKY MASI
MAILING ADDRESS 215 W 7th Ave.
Sparks, NV 89433

ADDRESS AT WELL LOCATION 18005 Northridge
Reno, NV 895 06

2. LOCATION NW ¼ SE ¼ Sec. 29 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Cold Springs (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay brown		0	3	3
Soft sandy clay brown		3	7	4
Clay		7	18	11
Sandy clay brown		18	25	7
Clay w/sands streaks		25	66	41
Sand	X	66	71	5
Clay		71	85	14
Sand & gravel		85	97	12
Clay		97	105	8
Sand w/clay streaks		105	118	13
Soft zone (sand)	X	118	121	3
Sandy clay		121	134	13
Sand & gravel	X	134	136	2
Sandy clay		136	141 →	

Date started 11-13-89, 19
Date completed 11-14-89, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 141 feet
inches
inches
Casing record 141' steel casing installed.
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	141 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 141 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 96 feet to 136 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow 35+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date November 15, 1989

NOV 29 '89 A9:20 STATE ENGINEER

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627