WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 326066
Permit No.
Basin

NOTICE OF INTENT NO. 35641

PRINT OR TYPE ONLY

1. OWNER BOB MADSON
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SE ¼ Sec. 34 T. 20 S N/S R. 53 E NYE County
PERMIT NO. (Issued by Water Resources) LOT 17 (Parcel No.) UNIT 4A (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	13	13
CALICHIE		13	15	2
CLAY		15	22	7
CALICHIE		22	23	1
CLAY		23	37	14
CALICHIE		37	38	1
CLAY		38	46	8
CALICHIE		46	49	3
CLAY		49	58	9
CALICHIE	W.B	58	61	3
CLAY		61	72	11
CALICHIE	W.B	72	73	1
CLAY		73	97	24
CALICHIE	W.B	97	98	1
CLAY		98	117	19
CALICHIE	W.B	117	119	2
CLAY		119	128	9
CALICHIE	W.B	128	134	6
CLAY		134	140	6

RECEIVED
NOV 7 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-26, 1989
Date completed 9-30, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
inches
inches
Casing record 140' 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAWCUT
Size perforation 1/8 INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 47 feet below land surface
Flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S+H DRILLING (Contractor)
Address HCR BOX 70706 PAHRUMP NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-2-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627