WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32673
Permit No.
Basin
NOTICE OF INTENT NO. 3585

PRINT OR TYPE ONLY

1. OWNER JAMES EPPERSON
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 19 T. 21 S N/S R. 54 E. NYE County
PERMIT NO. (Issued by Water Resources) LOT 67 (Parcel No.) GREEN SADDLE RANCH (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	9	9
CALICHIE		9	11	2
CLAY		11	23	12
CALICHIE		23	25	2
CLAY		25	31	6
CALICHIE		31	34	3
CLAY		34	52	18
CALICHIE	WB	52	53	1
CLAY		53	79	26
CALICHIE	WB	79	80	1
CLAY		80	91	11
CALICHIE	WB	91	93	2
CLAY		93	98	5
CALICHIE	WB	98	104	6
CLAY		104	113	9
CALICHIE	WB	113	115	2
CLAY		115	128	13
CALICHIE	WB	128	133	5
CLAY		133	140	7

RECEIVED
NOV 7 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-29, 1989
Date completed 11-3, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 140 feet
inches
inches
Casing record 140' 8 5/8 OD
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	0 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 50 feet

Perforations:
Type perforation FACTORY SAW CUT
Size perforation ⅛ INCH BY 3 INCH
From 140 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 49 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 66.6 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S+H Drilling (Contractor)
Address HCR 70 706 PAHRUMP NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22059
Nevada contractor's driller's number issued by the Division of Water Resources 1426
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-3-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627