



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 5022

1. OWNER Kay Rodriguez ADDRESS AT WELL LOCATION 2431 Pyle, Las Vegas, Nevada  
 MAILING ADDRESS 3340 South Toman, #100 Las Vegas, Nevada  
 2. LOCATION SE 1/4 Sec. 29 T. 22 N. R. 61 E. Clark County  
 PERMIT NO. NE 68713 | 177-29-701-003 Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. ~~DOMESTIC~~ PROPOSED USE  
 Irrigation  Test   
 Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	2	2
cemented gravel		2	125	123
brown sand & gravel		125	145	20
gravel	xx	145	172	27
gravel - Hard spot		172	175	3
gravel and brn sand		175	200	25
gravel	xxx	200	225	25
gravel		225	240	15
hard cemented gravel		240	260	20
cemented gravel	xxx	260	300	40

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 300 feet  
 Casing record 8 5/8 inch from 0 to 300 ft.  
 Weight per foot \_\_\_\_\_ Thickness .156  
 Diameter From To  
12" Hole inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
10" Hole inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
8" Casing inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 ft. feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation Torch cut  
 Size perforation 3/16" X 10"  
 From 180 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 NOV 2 1989  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 5-24-89, 19\_\_\_\_  
 Date completed 6-16-89, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Bailed 50 G.P.M. from 200 ft.  
20 Min. test.

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 130 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S. R. McKinney & Sons, Inc. Contractor  
 Address 1042 South Main St. Las Vegas, Nev Contractor  
 Nevada contractor's license number 2065 issued by the State Contractor's Board  
 Nevada contractor's driller's number 45 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources; the on-site driller 270  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 6-19-89