WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32696
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13437

1. OWNER Greg Davies Const
MAILING ADDRESS Box 22
Gardnerville, NV 12

ADDRESS AT WELL LOCATION
1050 Log Cabin
Gardnerville, Nevada

2. LOCATION NE ¼ SE ¼ Sec. 23 T. 12 N S R. 20 E. Douglas County
PERMIT NO. 23-234-09 Parcel No. Sagewood Estates
Issued by Water Resources (new apn # 1220-12-710-026) Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden - Clay w/ rock		0	8	8
Cemented pea gravels w/ Clay seams, tight		8	177	169
Gravels, fine to course 2-3 GPM	✓	169	181	4
Tight Clays, red, yellow coloring		181	211	30
Gravels, with fine to course sand - 20 GPM	✓	211	227	16
Clay, tight				
T.D. 230 ft				

23-234-090
1050 Log Cabin Rd
Legal
NE SE Sec 12 12N 20E
[redacted]
1220-12-710-0261

Date started Nov 22, 1989
Date completed Nov 28, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clear water to remove drill mud & to gravel pack. Blew 18-22 GPM from 200 ft 4 hours with 450-250 air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/2 to 60 inches Total depth 230 feet
9 7/8 inches
..... inches
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness 1.156

Diameter	From	To
6" inches	+2 feet	230 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 2 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 210 feet to 230 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 160 feet below land surface
Flow 18-22 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co
Contractor
Address Carson City, NV 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1422
Signed Clinton R Butts
By driller performing actual drilling on site or contractor
Date Nov 28, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627