WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32697
Permit No.
Basin 8-1051

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13447

1. OWNER Jim LIEBHERR / Tom CONNER
MAILING ADDRESS 1360 Porter
Minden, NV 89423

ADDRESS AT WELL LOCATION 2275 Sandoval
Gardnerville, NV 89410

2. LOCATION NE ¼ SW ¼ Sec. 17 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 35-170-11 (Parcel No.) ammonia (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	5	5
Clay & rocks		5	10	5
Clay, Sandy clay		10	120	110
Sand	X	120	145	25
clay		145	155	10
Sandy clay		155	180	25
Sticky green clay		180	222	42
Fractured volcanics	X	222	238	16
Sand	X	238	245	8
green clay		245	250	5

RECEIVED DEC 11 '89 A11:04 STATE ENGINEER'S OFFICE

Date started 11-29, 1989
Date completed 11-30, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 250 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .156

Diameter	From	To
6 inches	+1 feet	250 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation FACTORY SLOT
Size perforation 3/8" x 3" 6 per foot
From 210 feet to 250 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 60 feet below land surface
Flow —0— G.P.M. Approx 20-30 P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Energy Exploration Drilling (Contractor)
Address Po Box 1538 Minden, NV 89423 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21491
Nevada contractor's driller's number issued by the Division of Water Resources 1407
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1407
Signed Tom Woods (By driller performing actual drilling on site or contractor)
Date 11-30-89

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627