

OFFICE USE ONLY
 Log No. 32723
 Permit No. _____
 Basin _____
 NOTICE OF INTENT NO. 13732

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER JIM SALIM (Q & D CONSTRUCTION, INC.) ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2240 Schooner Cir. Anitra Drive
Reno, NV 89509 Reno, NV 89511
 2. LOCATION SE 1/4 NW 1/4 Sec. 2 T. 18N N/S R. 19 E Washoe County
 PERMIT NO. 41-29-15 SW Reno
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Gray volcanic rock		1	91	90
Brown volcanic rock		91	280	189
Soft zone (app 10 GPM)	X	280	290	10
Brown volcanic rock		290	305	15
Gray volcanic rock		305	314	9
Soft zone	X	314	330	16
Gray volcanic rock		330	358	28
Soft zone	X	358	367	9
Gray volcanic rock		367	373	6
Soft zone	X	373	377	4
Gray volcanic rock		377	391	14
Soft zone	X	391	394	3
Gray volcanic rock		394	400	6

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 400 feet
 _____ inches
 _____ inches
 Casing record 400' steel casing installed
 Weight per foot _____ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement grout
 Depth of seal _____ 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ 50 feet to _____ 400 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From _____ 315 feet to _____ 395 feet
 From _____ feet to _____ feet

Date started 12-27-89, 19_____
 Date completed 12-28-89, 19_____
 90 JAN -8 A10 52
 STATE CONTRACTOR

9. WATER LEVEL
 Static water level 242 feet below land surface
 Flow 98 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89511 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources 923
 Signed Wayne Drilling, Inc. By driller performing actual drilling on site or contractor
 Date January 2, 1990

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours