

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13731

1. OWNER JIM SALIM (Q & D CONSTRUCTION, INC.) ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS RYOYXB 2240 Schooner Drive _____
Reno, NV 89509 _____
Anitra Drive _____
Reno, NV 89511 _____

2. LOCATION SE 1/4 NW 1/4 Sec. 2 T. 18N N/S R. 19 E _____
Washoe County
 PERMIT NO. 41-29-18 _____
 Issued by Water Resources _____ Parcel No. _____ SW Reno _____
 Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown hard volcanic rock		1/2	35	34 1/2
Reddish brown volcanic rock		35	110	85
Red volcanic rock with some clay		110	163	53
Volcanic rock brown		163	295	132
Soft zone (app. 3 GPM)	X	295	297	2
Volcanic rock brown		297	330	33
Soft zone	X	330	340	10
Brown volcanic rock		340	343	3
Gray volcanic rock		343	352	9
Soft zone	X	352	364	12
Gray volcanic rock		364	384	20
Soft zone	X	384	393	9
Gray volcanic rock		393	400	7

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 400 feet

Casing record 400' steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement grout
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 400 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 313 feet to 393 feet
 From _____ feet to _____ feet

Date started 12-20-89, 19____
 Date completed 12-22-89, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>15</u>	<u>60</u>		

9. WATER LEVEL

Static water level 250 feet below land surface
 Flow 60 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Address P.O. Box 12370, Reno, NV 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] by driller performing actual drilling on site or contractor
 Date December 27, 1989

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours