

NOTICE USE ONLY  
 Log No. 32793  
 Permit No. \_\_\_\_\_  
 Basin 4-44

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 13156

PRINT OR TYPE ONLY

1. OWNER D. E. W INC ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 3111 EIKO \_\_\_\_\_  
 2. LOCATION SW 1/4 SW 1/4 Sec 36 T 36 N N/S R. SE E EIKO County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. 06-334-70-1 Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sandy Loam</u>		<u>0</u>	<u>3</u>	
<u>Clay light TAN</u>		<u>3</u>	<u>38</u>	
<u>Cravel</u>		<u>38</u>	<u>41</u>	
<u>Clay light TAN</u>		<u>41</u>	<u>64</u>	
<u>Cravel</u>		<u>64</u>	<u>65</u>	
<u>Clay light TAN</u>		<u>65</u>	<u>128</u>	
<u>SAND &amp; Cravel</u>	<u>Water</u>	<u>128</u>	<u>137</u>	<u>9</u>

DATE: DEC 29 1989 TIME: 9:47  
 STATE ENGINEERING DEPT.

8. WELL CONSTRUCTION  
 Diameter 10" inches Total depth 137 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6" SFEEL  
 Weight per foot \_\_\_\_\_ Thickness 203  

Diameter	From	To
<u>6</u> inches	<u>71</u> feet	<u>137</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 55 feet  
 Gravel packed: Yes  No   
 Gravel packed from 55 feet to 137 feet  
 Perforations:  
 Type perforation slots  
 Size perforation 3/16 - 3"  
 From 112 feet to 137 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 11-2-89, 19\_\_\_\_  
 Date completed 11-5-89, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 19-20 Draw down 60 feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling Co Contractor  
 Address 355 West River St EIKO Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 20684  
 Nevada contractor's driller's number issued by the Division of Water Resources 904  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1584  
 Signed Shane C. Fitting  
 By driller performing actual drilling on site or contractor  
 Date 11-30-89