WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

TTR - #3B
PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32808
Permit No.
Basin
NOTICE OF INTENT NO.

1. OWNER U.S. Air Force c/o Desert Research
MAILING ADDRESS Institute, U.N.R.
Controllers Office, Reno, NV 89557
ADDRESS AT WELL LOCATION Tonopah Test Range

2. LOCATION NW ¼ SE ¼ Sec. 13 T 1 N/S R 46 E Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & gravel | | 0 | 80 | 80 |
| Coarse sand, fine gravel, volcanic rock, pebbles | | 80 | 275 | 195 |
| Sand, green & white clay | | ~~2775~~ 275 | 300 | 25 |

RECEIVED
DEC 28 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

RECEIVED
DEC 29 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started December 24, 1984
Date completed January 11, 1985

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | 210 | 222.47 | 24 |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 18 inches Total depth 300 feet
24 inches to 60'
inches
Casing record
Weight per foot Thickness .250

| Diameter | From | To |
|---|---|---|
| 20 inches | 0 feet | 60 feet |
| 12 inches | 0 feet | 300 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 300 feet

Perforations:
Type perforation Stainless steel screen
Size perforation 50 slot
From 145 feet to 284 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 111 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CVO., INC. (Contractor)
Address 4185 W. Harmon Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856
Signed Richard K. Thompson
By driller performing actual drilling on site or contractor
Date December 19, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627