SION OF WATER RESOURCES
ENT'S COPY
RILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32809
Permit No.
Basin 10-117

NER FRANK E SMITH ADDRESS DYER NEV 89010

2. LOCATION SE ¼ SW ¼ Sec. 6 T. 4 N/S R. 36 E. ESMERALDA County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock & Sand		0	30	30
Hard Clay		30	60	30
Rock + gravel	water	60	68	8
Rocky Clay		68	80	12
Rock & sand	water	80	84	4
Hard Clay		84	105	21
Rock & Sand	water	105	109	4
Hard Clay		109	140	21
Rock & gravel	water	140	147	7
Hard Rocky Clay		147	160	13

'89 DEC 14 A10:42
RECEIVED
STATE ENGINEERS OFFICE

Date started 11/18, 1989
Date completed 11/20, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 160 feet
Casing record
Weight per foot Thickness 3/16

Diameter	From	To
6" inches	0 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 160' feet

Perforations:
Type perforation MACHINE
Size perforation 1/8 X 2
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 58 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name W S WRIGHT
Address HCR 15 DYER NEV 89010
Nevada contractor's license number 5566
Nevada driller's license number 1108
Signed W S Wright
Date 12/10/89

USE ADDITIONAL SHEETS IF NECESSARY

O-627