WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32829
Permit No. 51800
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2803

1. OWNER Regina M. Whalen
MAILING ADDRESS c/o Fulstone Enterprises
940 So. Highland, Las Vegas, NV 89106

ADDRESS AT WELL LOCATION
Wigwam

2. LOCATION SE ¼ NW ¼ Sec. 15 T. 22 S R. 60 E Clark County
PERMIT NO. 51800 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐ Quasi

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	40	40
Clay & gravel		40	100	60
Red sandy clay		100	160	60
Brown sandy clay		160	180	20
Clay & cemented gravel		180	300	120
White clay		320	340	20
Red shale & snady clay		340	400	60
Sandy clay		400	440	40
Clay & gravel		440	480	40
Red sandstone		480	520	40
Gravel		520	540	20
Red sandstone		540	560	20
Red sandstone & clay		560	580	20
Red clay & gravel		580	600	20
Gravel		600	650	50

RECEIVED
DEC 22 1989
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started February 1, 1989
Date completed February 15, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. 12 3/4" WELL CONSTRUCTION
Diameter ~~12x~~ inches Total depth 650 feet
inches
inches
Casing record
Weight per foot Thickness .156

Diameter	From	To
8 inches	+1 feet	650 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 650 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2½" 8 rows
From 530 feet to 610 feet
From 630 feet to 650 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 480 feet below land surface
Flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 W. Harmon, Las Vegas, NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada contractor's driller's number issued by the Division of Water Resources 290
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489
Signed Richard R. Thompson (By driller performing actual drilling on site or contractor)
Date November 21, 1989

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627