WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 32869
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14743

1. OWNER BRYANT PARKER
MAILING ADDRESS 330 A 4th
SPARKS, NEVADA

ADDRESS AT WELL LOCATION 7472 Old 395 N
Carson City, NV

2. LOCATION SW ¼ SW ¼ Sec. 11 T. 16 N/S R. 19 E. Douglas County

PERMIT NO. [illegible] Issued by Water Resources | Parcel No. | Subdivision Name: None

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden with Sands		0	10	10
Sands with Fine gravel		10	30	20
green clay with seams of G.D.		30	120	90
G.D. and light clay seams		120	140	20
(Note) Left 10' feet of pregrade to stop sand form coming in well Bottom				
T.D. 140 Ft.				

Date started 1/25, 1990
Date completed 1/29, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with clear water. Developed with Air. 30 to 40 gal per min. at 80'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12" to 60' inches, 9 1/2 inches, inches Total depth 140 feet
Casing record 6 5/8" O.D. Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 2 feet below land surface
Flow 35+ G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/30/90

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (0)-62