

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 13733

PRINT OR TYPE ONLY

1. OWNER FRANK RILEY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 15860 LaEscula Ct. 3655 Right Hand Canyon Road  
Morgan Hill, CA 95037 Reno, NV 89510  
 2. LOCATION SE 1/4 SE 1/4 Sec 29 T 22N N/S R. 22 E Washoe County  
 PERMIT NO. 77-300-22 Palomino Valley  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Test Hole #1 No water no casing installed.				
Brown clay		1	3	3
Light brown clay		3	17	14
Brown clay		17	35	18
Gray clay		35	97	62
Volcanic bolder		97	99	2
Gray clay		99	173	74
Purple sandy clay		173	255	82
Purple volcanic rock		255	280	25
Purple sandy clay		280	286	6
Gray clay		286	319	33
Reddish brown clay		319	327	8
Green volcanic rock				
w/streaks of clay		327	356	29
Multi-color clays with soft zone(NO WATER)		356	405	49
Gray clay		405	450	45
Started 1-3, complete 1-6-90				
HOLE #2 complete well.				
Brown clay with D.G.		0	7	7
Gray hard granite		7	85	78
Fracture granite	X	85	93	8
Gray granite		93	109	16
Fractured granite	X	109	123	14
Granite		123	125	2

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 125 feet

Casing record 125' steel casing installed.

Weight per foot \_\_\_\_\_ Thickness .156

Diameter	From	To
<u>06 5/8</u> inches	<u>0</u> feet	<u>125</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement grout

Depth of seal 50 feet

Gravel packed: Yes  No

Gravel packed from 50 feet to 125 feet

Perforations:

Type perforation factory sawed slot

Size perforation 3/32 x 3 x 5 around

From 80 feet to 120 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 1-8-90, 19\_\_\_\_  
 Date completed 1-9-90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
			<input checked="" type="checkbox"/>

NOTE: Test hole #1 will be abandone as soon as mashine is available. You will be notified.

9. WATER LEVEL

Static water level 62 feet below land surface

Flow 137 G.P.M. P.S.I. \_\_\_\_\_

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc.  
Contractor

Address P.O. Box 12370, Reno, NV 89510  
Contractor

Nevada contractor's license number 22549  
 issued by the State Contractor's Board.

Nevada contractor's driller's number \_\_\_\_\_  
 issued by the Division of Water Resources 908

Nevada driller's license number \_\_\_\_\_ issued by the Division of Water Resources the on-site driller 923

Signed [Signature]  
 by driller performing actual drilling on site or contractor

Date January 12, 1990

BAILER TEST

G.P.M.	Draw down	feet	hours