

OFFICE USE ONLY
 Log No. 32927
 Permit No. _____
 Basin 2-4a
 NOTICE OF INTENT NO. 13755

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER ADOBE HEIGHTS, INC. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 430
Elko, NV 89801
 2. LOCATION NW 1/4 SE 1/4 Sec. 1 T. 34N N/S R. 54 E ELKO County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt & Clay		0'	10'	10'
Shale, Silty, Brown		10'	60'	50'
Siltstone		60'	120'	60'
Shale, Grey		120'	160'	40'
Shale & Siltstone		160'	240'	80'
Shale & Siltstone		240'	270'	30'
Shale & Sandstone, some black shale		270'	280'	10'
Siltstone, pink, br. and green		280'	300'	20'
Rhyolite, red	x	300'	310'	10'
Siltstone, brown		310'	360'	50'
Shale, grey		360'	440'	80'
Siltstone, grey	x	440'	480'	40'
Shale & Sandstone, grey		480'	500'	20'

90 FEB -1 18:05
STATE ENGINEERS (711)

8. WELL CONSTRUCTION
 Diameter 10 inches Total depth 500 feet
8 inches
 _____ inches
 Casing record _____
 Weight per foot _____ Thickness 156
 Diameter From To
6 5/8 inches +1 1/2 feet 380 feet
 _____ inches 400 feet 460 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type _____
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 500 feet
 Perforations:
 Type perforation Mill slot
 Size perforation 1/8 x 3
 From 380 feet to 400 feet
 From 460 feet to 500 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started December 19, 1989
 Date completed January 3, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow Test	6		

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 160 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HACKWORTH DRILLING, INC. Contractor
 Address P.O. Box 850 Elko, NV 89801 Contractor
 Nevada contractor's license number 020582
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1166
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1654
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 29 Jan 90