WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33000
Permit No. 46688
Basin 10-122

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13864

1. OWNER HARRY BROWN
MAILING ADDRESS P. O. BOX GABBS, NV 89409
ADDRESS AT WELL LOCATION GABBS, NV

2. LOCATION SW ¼ SW ¼ Sec. 17 T. 13 N/S R. 34 E. CHURCHILL County
PERMIT NO. 46688 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [ ] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [X]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	24	24
BOULDERS		24	26	02
SAND & GRAVEL		26	29	03
BOULDERS		29	52	23
CEMENTED GRAVEL		52	118	66
BROWN SAND		118	135	17
GRAVEL		135	158	23
ROCK		158	160	02
GRAVEL		160	250	90
ROCK	X	250	340	90

Replacement of log # 8577

Date started JANUARY 24, 1990
Date completed JANUARY 29, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	@15 GPM		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 340 feet
inches
inches
Casing record 6 5/8 x 340
Weight per foot 12.9 Thickness .188

Diameter	From	To
10 inches	0 feet	340 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes [ ] No [X]
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32 X 3
From 318 feet to 338 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 270 feet below land surface
Flow -0- G.P.M. ..... P.S.I.
Water temperature 140 °F Quality POOR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 FALLON, NV89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
Signed ..... (By driller performing actual drilling on site or contractor)
Date FEBRUARY 6, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627