

OFFICE USE ONLY
 Log No. 33031
 Permit No. 7-926 (21)
 Basin 7-926
 NOTICE OF INTENT NO. 13738

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER ARNOLD & SALLY ETCHEBERRY ADDRESS AT WELL LOCATION same
 MAILING ADDRESS 8850 Cassillis Drive
Reno, NV 89506
 2. LOCATION NW 1/4 NW 1/4 Sec 4 T 20N R 19 E Washoe County
 PERMIT NO. 20N Issued by Water Resources Parcel No. 20N Subdivision Name Lemmon Valley

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Cable <input type="checkbox"/>
Recondition <input type="checkbox"/>	Irrigation <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
Deepen <input checked="" type="checkbox"/>	Industrial <input type="checkbox"/>	Other <input type="checkbox"/>
Other <input type="checkbox"/>	Test <input type="checkbox"/>	Air <input type="checkbox"/>
	Stock <input type="checkbox"/>	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Rust with sands (app. 12 GPM @ bottom)		174	175	1
Soft weathered granite		175	195	20
Hard granite		195	202	7
Fracture	X	202	207	5
Hard gray granite		207	215	8
Fracture	X	215	216	1
Hard gray granite		216	221	5
Fracture	X	221	223	2
Hard gray granite		223	225	2

8. WELL CONSTRUCTION

Diameter 6 & 5 inches Total depth 225 feet
 inches
 inches
 Casing record 225' steel liner installed.
 Weight per foot _____ Thickness .134
 Diameter _____ From _____ To _____
 5"OD inches 0 feet 225 feet
 inches feet feet
 Surface seal: Yes No Type N/A
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 173 feet to 225 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 165 feet to 225 feet
 From _____ feet to _____ feet

Date started 1-31-90, 19____
 Date completed 1-31-90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 35 feet below land surface
 Flow 40+ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne Drilling, Inc. By driller performing actual drilling on site or contractor
 Date February 6, 1990