

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12525

1. OWNER WIND MOUNTAIN MINING, INC. ADDRESS AT WELL LOCATION South  
 MAILING ADDRESS P.O. BOX 160 17 MILES NORTH OF GERLACH  
EMPIRE, NEVADA 89405

2. LOCATION NW 1/4 NE 1/4 Sec. 4 T. 29 (N/S R. 23 E. WASHOE County

PERMIT NO. MM65/52844  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE PW#3  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Large boulders, sand gravel, dirt, silt		0	20	20
Large boulders, sand gravel, gray clay & red clay		20	50	30
Light & dark blue clay with broken rock chips & boulders		50	80	30
Black, red, green, gray, lava rock with gray clay layers		80	120	40
Black gray lava rock		120	160	40
Green, black & gray rock with trace of gray clay		160	280	120
Dark & light gray rock with trace of gray clay		280	300	20

8. WELL CONSTRUCTION  
 Diameter 19-1/2 inches Total depth 300 feet  
 Casing record 14 inch O.D. x .250 wall  
 Weight per foot 42.05 Thickness  

Diameter	From	To
<u>14</u> inches	<u>+1</u> feet	<u>300</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

 Surface seal: Yes  No  Type cement sand grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 300 feet  
Chevreux 3/8 inch minus  
 Perforations:  
 Type perforation 14 inch O.D. core 10 steel  
 Size perforation full flo shutter screen  
 From 60 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started January 5, 1990  
 Date completed January 24, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>30</u>	<u>STAT</u>		

BAILER TEST  
 G.P.M. Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature hot °F Quality poor

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CHAS. SARGENT IRRIGATION INC.  
 Address 9955 N. VIRGINA STREET, RENO, NV. 89506  
 Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada contractor's driller's number issued by the Division of Water Resources 1391  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1578  
 Signed Nancy McCarver  
 By driller performing actual drilling on site or contractor  
 Date FEBRUARY 8, 1990