

OFFICE USE ONLY
 Log No. 33079
 Permit No. 9108T
 Basin 1
 NOTICE OF INTENT NO. 13955

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Don Steneri ADDRESS AT WELL LOCATION # 12 Bum Steer Rd
 MAILING ADDRESS 1190 Hwy 208 Parcel 2 of Map 72486
Yerington, Nv 89447
 2. LOCATION NW 1/4 NW 1/4 Sec. 13 T. 12 N/S R. 25 E Lyon County
 PERMIT NO. 12-311-04 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Green & black rock highly fractured		0	37	37
Brown & black rock highly fractured		37	79	42
Black & white granite highly fractured		79	115	36
White & black granite [hard] fractured		115	125	10
White & black granite some green & brown rock fractured [Medium hard]		125	219	91
T.D. 219 feet				

8. 10" - 54' WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 219 feet
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156
 Diameter From To
6 5/8 inches + 1 feet 219 feet
 Surface seal: Yes No Type grout
 Depth of seal 54 feet
 Gravel packed: Yes No
 Gravel packed from 54 feet to 219 feet
 Perforations:
 Type perforation factory
 Size perforation 1/8 X 3
 From 199 feet to 219 feet

9. WATER LEVEL
 Static water level 120 feet below land surface
 Flow 20+ G.P.M. P.S.I.
 Water temperature cold Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number issued by the State Contractor's Board 15291
 Nevada contractor's driller's number issued by the Division of Water Resources 1132
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 4/4/90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours