

OFFICE USE ONLY  
 Log No. 33081  
 Permit No. 49958  
 Basin B-105

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1.0061

1. OWNER WESTERN NEVADA PROPERTIES, INC. ADDRESS AT WELL LOCATION WINHAVEN  
 MAILING ADDRESS P.O. BOX 2647 MINDEN, NEVADA 89423  
 MINDEN, NEVADA 89423  
 2. LOCATION SE 1/4 NW 1/4 Sec. 29 T. 13 (N/S R. 20 E. DOUGLAS County  
 PERMIT NO. 49959 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE #6  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil & large gravel		0	20	20
Large gravel		20	90	70
Clay w/ layers of gravel		90	140	50
Fine to medium gravel & course sand		140	205	65
Sand, blue clay w/ fine gravel & sand layers		205	272	67
Medium gravel w/ clay layers		272	300	28
Course sand & fine gravel w/ thin layers of clay		300	340	40

8. WELL CONSTRUCTION

Diameter 24 inches Total depth 340 feet

Casing record 16 inch O.D. x 5/16 inch wall  
 Weight per foot #54.45 Thickness           

Diameter	From	To
<u>16</u> inches	<u>+1</u> feet	<u>340</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes  No  Type cement sand slurry  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 340 feet  
 Chevreux quartz pebbles 1/8 inch x 1/4 inch

Perforations:  
 Type perforation 16 inch wire wrap stainless steel screen  
 Size perforation .080 inch  
 From 150 feet to 210 feet  
 From 250 feet to 330 feet  
 From            feet to            feet  
 From            feet to            feet

Date started March 13, 1990  
 Date completed March 31, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>2200</u>	<u>25</u>	<u>24</u>

9. WATER LEVEL  
 Static water level 7 feet below land surface  
 Flow            G.P.M.            P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CHAS. SARGENT IRRIGATION INC. Contractor  
 Address 9955 N. Virginia st., Reno, Nv. 89506 Contractor  
 Nevada contractor's license number 21246 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1391 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1388  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date April 4, 1990

BAILER TEST

G.P.M.            Draw down            feet            hours  
 G.P.M.            Draw down            feet            hours  
 G.P.M.            Draw down            feet            hours