

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13501

1. OWNER Waldo Brown ADDRESS AT WELL LOCATION Same as legal
 MAILING ADDRESS 120 N. Nevada St. Yerington, NV 89447
 2. LOCATION NW 1/4 SE 1/4 Sec. 4 T. 13 N. R. 26 E. Lyon County
 PERMIT NO. 14-631-42 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>top soil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>coarse sand</u>		<u>5</u>	<u>17</u>	<u>12</u>
<u>clay/gravel</u>		<u>17</u>	<u>65</u>	<u>48</u>
<u>coarse sand</u>		<u>65</u>	<u>75</u>	<u>10</u>
<u>coarse sand/clay</u>		<u>75</u>	<u>78</u>	<u>3</u>
<u>coarse sand/gravel</u>	<input checked="" type="checkbox"/>	<u>78</u>	<u>99'3"</u>	<u>21'3"</u>

8. WELL CONSTRUCTION
 Diameter 12 5/8 inches Total depth 100'3" feet
 Casing record _____
 Weight per foot _____ Thickness .156
 Diameter 8 5/8 inches From +1 feet To 99'3" feet
 Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 99'3" feet
 Perforations:
 Type perforation sawed
 Size perforation 3 3/8" x 3" x 8 rows
 From 79'3" feet to 99'3" feet

Date started 12-18 1989
 Date completed 12-23 1989

9. WATER LEVEL
 Static water level 17 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
/			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 160 N. Bybee Lane Yerington NV 89447 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 156646
 Nevada contractor's driller's number issued by the Division of Water Resources 530/870
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 530
 Signed Billy Ogden By driller performing actual drilling on site or contractor
 Date 3-11-90

BAILER TEST
 G.P.M. 20 Draw down 2 feet 1/2 hour
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours