WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33090
Permit No.
Basin 6-89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14151

1. OWNER ALAN BENNETT
MAILING ADDRESS 4385 DRAKE WAY Carson City, NV
ADDRESS AT WELL LOCATION 4385 DRAKE WAY CARSON CITY, NV

2. LOCATION SE ¼ NE ¼ Sec. 5 T. 16 N/S R. 20 E. WASHOE County
PERMIT NO. ~~WCty 3543~~ (Issued by Water Resources) Parcel No. NEW WASHOE CITY #5 (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ AIR

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	5	5
SANDSTONE, HARD, Yellow		5	15	20
BLUE HARD FINE GRAINED GRANITE		15	86	71
FRACTURED HARD GRANITE	✓	86	98	12
HARD SOLID BLUE TO WHITE GRANITE		98	105	7
FRACTURED GRANITE	✓	105	107	2
HARD, SOLID GRANITE		107	115	8
TD 115 FT				

Date started Feb 15, 1990
Date completed Feb 21, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Completed with air & gravel packed. Blew 25 gpm from 90'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 to 60 inches Total depth 115 feet
9 3/4 inches
5/2 inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	115 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type CONCRETE
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 115 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3"
From 95 feet to 115 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 45 feet below land surface
Flow 25 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] (By driller performing actual drilling on site or contractor)
Date Feb 21, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627