

*dccb*

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 13956

PRINT OR TYPE ONLY

1. OWNER Craig Curtis ADDRESS AT WELL LOCATION 4805 North Townside Dr  
 MAILING ADDRESS P. O. Box 18253 Lot 2 Block A Callahan  
Reno, Nv 89511  
 2. LOCATION SW SE  $\frac{1}{4}$  Sec. 2 T. 17 N/S R. 19 E Washoe County  
 PERMIT NO. 045-690-10 Old Galena # 1  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	6	6
Cobbles & boulders		6	18	12
D.G. brown with some fine sands		18	38	20
Multi-colored course gravels & fine brown sand		38	150	112
T.D. 150 ft.				

90 APR -5 P 4 36  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. 10" -150 WELL CONSTRUCTION

Diameter 10 inches Total depth 150 feet

Casing record 6 5/8 inch  
 Weight per foot 10.78 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>+1</u> feet	<u>150</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes  No  Type Neat cement  
 Depth of seal 52 feet  
 Gravel packed: Yes  No   
 Gravel packed from 52 feet to 150 feet

Perforations:  
 Type perforation screen  
 Size perforation .030  
 From 120 feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3/21/90, 19\_\_\_\_  
 Date completed 3/22/90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air to clean and develop.</u>			

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level 42 feet below land surface  
 Flow 20+ G.P.M. P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
Contractor  
 Address 625 Spice Islands Dr Suite L Sparks, Nv  
Contractor 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources  
 Nevada driller's license number issued by the 1509  
 Division of Water Resources, the on-site driller  
 Signed Roger M. Thrall  
By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 3/26/90