WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. B3097
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14959

1. OWNER Glen Horner
MAILING ADDRESS HC-30 Box 705
Chiloquin, Oregon 97624

ADDRESS AT WELL LOCATION Doc 29768 & 29
Unit #1 Lot #11
Dayton, Nevada

2. LOCATION NW ¼ SE ¼ Sec. 27 T. 17 N/S R. 22 E. Lyon County

PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name: Pine Nuts Estates

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Clays, Cemented Scoria type rock, small to 6"		4	65	61
Scoria, badly fractured Carring H2O	✓	65	100	35
T.D. = 100'				

'90 MAR 13 A9:15
STATE ENGINEERS OFFICE

Date started March 7, 1990
Date completed March 8, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed with air for 2 hours Blowing 20 GPM from 90'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 to 50' inches Total depth 100 feet
8 3/4 inches
..... inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	100 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 100 feet

Perforations:
Type perforation Factory slot
Size perforation 3/32" x 3"
From 80 feet to 100 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 37 feet below land surface
Flow 20 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DE H Pump Co (Contractor)
Address Carson City, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23795
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 9, 1990

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627