

OFFICE USE ONLY
 Log No. 38120
 Permit No. 7-926
 Basin 7-926

b2000

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13945

1. OWNER Bob Thompson ADDRESS AT WELL LOCATION 9215 N Virginia St
 MAILING ADDRESS 9215 N Virginia St 9215 N Virginia St
Reno, Nv 89506 Lot 5 of Survey 138
 2. LOCATION SE 1/4 NW 1/4 Sec. 16 T. 20 N/S R. 19 E. Washoe County
 PERMIT NO. 82-660-22 Parcel No. - Subdivision Name -
 Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Multicolored gravels with some find sands		3	12	9
Multi-colored gravels with some brown clay and fine sand		12	37	25
Coarse multi-colored gravel with some brown clay & fine sand		37	76	39
Brown clay [sticky]		76	84	8
Multi-colored gravel with some brown clay		84	223	139
Blue green multi rock with some find sand		223	257	34
Brown sticky clay with some multi-colored gravels & fine sand		257	282	25
Green clay with some fine sand		282	362	80
Blue green white & red rock with some blue clay & fine sand		362	367	5
Blue clay		367	441	74
Blue black red & tan coarse gravels with some fine sand		441	477	36
T.D. 477 ft				

8. 10"-54" WELL CONSTRUCTION
 Diameter 8 1/2 inches Total depth 477 feet
 Casing record 6 5/8 inch
 Weight per foot 10.78 Thickness .156
 Diameter 6 5/8 inches From +1 feet To 477 feet
 Surface seal: Yes No Type neat cement
 Depth of seal 54 feet
 Gravel packed: Yes No
 Gravel packed from 54 feet to 477 feet
 Perforations:
 Type perforation Factory [Double]
 Size perforation 3/32 X 3
 From 337 feet to 357 feet
 From 457 feet to 477 feet

Date started 2/12/90
 Date completed 3/1/90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blew with air</u>	<u>clear</u>	<u>and develop.</u>	

BAILER TEST

G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours

9. WATER LEVEL
 Static water level 320 feet below land surface
 Flow 20+ G.P.M. P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc.
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the onsite driller 1509
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 3/2/90