WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 331883
Permit No. 50738
Basin 10-149

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Stone Cabin Partnership
MAILING ADDRESS PO Box 648
Tonopah NV 89049

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SW ¼ Sec. 8 T 4 N/S R. 47 E Nye County
PERMIT NO. 50738 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☑ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	7	
Blue Clay		7	9	
Sand + Gravel (No Clay)	XX	9	30	
Clay or Silt 10 To 15% mix	XX	30	120	
Sand and Gravel	XX			
Sand + Gravel	XX	120	125	
50% Clay or Silt 50% S+G	XX	125	127	
15% Clay or Silt 85% S+G	XX	127	160	
25% Clay or Silt 75% S+G	XX	160	203	
Gravel on Top of Bedrock	XXX	203	207	
Malapie Bedrock		207	224	
Drilled hole 1-16-21-90				
Admit holes not straight 1-21-2-5-90				
Straighten hole install Pipe Gravel				
+ Cement 2-6-2-10-90				

Date started 1 16, 1990
Date completed 2 10, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 24" inches Total depth 224 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness

Diameter	From	To
16 inches	+ 2 feet	210 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement Slurry
Depth of seal 42 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 53 feet to 224 feet

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 53 feet to 210 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 2' feet below land surface
Flow 300 To 1000 G.P.M. Air Lift P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson (Contractor)
Address 10760 Grass Valley Rd (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada contractor's driller's number issued by the Division of Water Resources 1375
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2-10-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627