WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 33214
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14063

1. OWNER Berry Jobe,
MAILING ADDRESS Box 1183
Minden, NV 89423

ADDRESS AT WELL LOCATION
1331 Homestead

2. LOCATION NE ¼ NE ¼ Sec. 5 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 35-342-01 (Parcel No.) Fish Springs (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ gravels + small boulders		0	6	6
Gravels + boulders w/ Cemented Clays		6	100	94
Pea gravels w/ Clay Seams 3-4 GPM	✓	100	130	30
Cemented Sand + gravels		130	170	40
Gravels, fine to course to fine Sand 30 GPM	✓	170	180	10
T.D. 180				

Date started March 5, 1990
Date completed March 7, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clean water to remove Mud. Developed out with 150-250 air Blowing 25-30 GPM From Night			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 1/4 inches Total depth 180 feet
9 7/8 inches
inches
Casing record 6 5/8" Steel
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 180 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 160 feet to 180 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow 25-30 G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rawhack Drilling Inc. (Contractor)
Address Pt #3 2668 Fuller, Minden, NV 89423 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 021268
Nevada contractor's driller's number issued by the Division of Water Resources 1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joey Betts
By driller performing actual drilling on site or contractor
Date March 9, 1990

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 11-85) (O)-627