

OFFICE USE ONLY  
 Log No. 33225  
 Permit No. \_\_\_\_\_  
 Basin 8-105

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTEREST NO. 14060

1. OWNER Richard Reed ADDRESS AT WELL LOCATION Johnson Ln & Highway 21  
 MAILING ADDRESS 718-A Wagon Dr. Sand. Co. 89410

2. LOCATION 92  $\frac{1}{4}$  1 E  $\frac{1}{4}$  Sec. 5 T. 13 N/S R. 20 E. Douglas County  
 PERMIT NO. 23-021-10 Issued by Water Resources Parcel No. Johnson Ln area Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Overburden</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Sand w/ fine clay seams</u>		<u>5</u>	<u>90</u>	<u>85</u>
<u>Gravel's w/ fine to coarse sand</u>	<input checked="" type="checkbox"/>	<u>90</u>	<u>120</u>	<u>30</u>
T.D. <u>120 ft</u>				
90 APR 30 AM 10:56 RECEIVED STATE ENGINEERS DIVISION				

8. WELL CONSTRUCTION

Diameter 12 3/4 inches Total depth 120 feet

Casing record 8 5/8 steel  
 Weight per foot 14.6 Thickness 1.88

Diameter	From	To
<u>8 5/8</u> inches	<u>+2</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 120 feet

Perforations:  
 Type perforation Factory Mill slot  
 Size perforation 3/32" x 3"  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started March 9 1990  
 Date completed March 12 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Flushed to remove drill mud &amp; gravel pack.</u>			
<u>Developed with 250-450 cfm. Blew for 2 hrs, 50+ GPM</u>			

9. WATER LEVEL

Static water level \_\_\_\_\_ feet below land surface  
 Flow 50 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gerald Phinnell, Inc. Contractor  
 Address 2500 W. 11th St. Las Vegas, NV 89115 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board. 671160  
 Nevada contractor's driller's number issued by the Division of Water Resources. 1350  
 Nevada driller's license number issued by the Division of Water Resources. 1535  
 Signed Gerald Phinnell By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____