

OFFICE USE ONLY  
 Log No. 33226  
 Permit No. \_\_\_\_\_  
 Basin B-105

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 14065

PRINT OR TYPE ONLY

1. OWNER Buckeye Creek ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Box 725  
Minden, NV  
 2. LOCATION NE 1/4 NW 1/4 Sec. 23 T. 13 N/S R. 20 E. County Douglas  
 PERMIT NO. W-1000# M-0-214 Parcel No. \_\_\_\_\_  
 Issued by Water Resources Subdivision Name Buckeye Creek

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	5	
Sand		5	10	
Sand		10	15	
Sand		15	20	
Sand		20	25	
Sand		25	30	
Sand & gravel		30	35	
Sand & gravel		35	40	
Sand & gravel		40	45	
Sand		45	50	
Sand & gravel		50	55	
Sand & gravel		55	60	
Sand		60	65	
Sand & gravel		65	70	
gravel sand & rocks		70	75	
Clay & sand		75	80	
Clay		80	85	
Clay		85	90	
SAND CLAY		90	95	
Clay & sand		95	100	
Sand (first water at 100')		100	105	
Sand & clay		105	110	
Sand		110	115	
Sand		115	120	
Clay & sand		120	125	
Clay & sand		125	130	
Clay sand & gravel		130	135	

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 160 feet  
 Casing record ASTM A-53-A 160' 6"  
 Weight per foot Sp Thickness 156  

Diameter	From	To
6 inches	0 feet	160 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 160 feet to 50 feet  
 Perforations:  
 Type perforation factory Perf  
 Size perforation 3" X 5/32"  
 From 160 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-5 19 90  
 Date completed 3-9 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Clay & sand		135 - 140	
Clay & sand		140 - 145	
Clay		145 - 150	
Clay		150 - 155	
Clay & sand		155 - 160	

well cleaned by NR AT 20 gpm for 2 hrs  
 BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 51 feet below land surface  
 Flow 20 ft G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kauchack Drilling Tax Contractor  
 Address 2668 Fuller Minden NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board #021268  
 Nevada contractor's driller's number issued by the Division of Water Resources #1380  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1485  
 Signed Michael Allen  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_