

OFFICE USE ONLY
 Log No. 33229
 Permit No. _____
 Basin 105-CARSON V.

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 12737

1. OWNER Jim Martin ADDRESS AT WELL LOCATION 3649 Summer Hill Rd.
 MAILING ADDRESS P.O. Box 7116
Indio Valley, N. 89450
 2. LOCATION NW 1/4 SE 1/4 Sec. 6 T 14 N 20 E Douglas County
 PERMIT NO. 13-103-13 Parcel No. _____
Jacks Valley Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand (DG)		0	5	
Sand & Rocks		5	15	
Sand		15	45	
Sand & Rocks		45	55	
Sand		55	65	
Sand & Rocks		65	70	
Sand		70	100	
Rock		100	105	
Sand & Rocks		105	130	
Rocks (sandstone)	X	130	145	
Sandstone	X	145	175	
Sand	XX	175	180	
Sandstone	XX	180	195	
Rocks & sandstone	XX	195	220	

'90 APR 30 AM 5:06
 STATE ENGINEERS JEFF

8. WELL CONSTRUCTION
 Diameter 10 inches Total depth 220 feet
 _____ inches
 _____ inches
 Casing record ARM 53 6" 220'
 Weight per foot SpL Thickness (0.156) (160-250)

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>220</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 220 feet to 50 feet
 Perforations:
 Type perforation Factory Foot
 Size perforation 3" X 5/32"
 From 220 feet to 200 feet
 From _____ feet to _____ feet

Date started 3-10, 19 90
 Date completed 3-15, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>100R</u>	<u>20 gpm</u>	<u>-</u>	<u>2 hrs.</u>

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 110 feet below land surface
 Flow 20 G.P.M. P.S.I. _____
 Water temperature Calc. °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Knoxbrook Drilling Inc.
 Address 2668 Fuller Minecon N. 89423
 Nevada contractor's license number issued by the State Contractor's Board #021268
 Nevada contractor's driller's number issued by the Division of Water Resources #1380
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller #1455 #1495
 Signed Michael Allen
 By driller performing actual drilling on site or contractor
 Date 3-17-90