

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15204

1. OWNER Young Enterprizes ADDRESS AT WELL LOCATION 35 Darilyn Lane  
 MAILING ADDRESS Box 18196 New Washoe City  
Reno, Nevada 89511 Carson City, Nevada  
 2. LOCATION NW 1/4 NW 1/4 Sec. 31 T. 17 S. R. 20 E. Washoe County  
 PERMIT NO. W County 005812 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name New Washoe City

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other  mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden and blow sand		0	8	8
Loose, fine to course sand		8	29	21
Clay seam with sand		29	35	6
Sand, fine to course		35	87	52
Clay, firm, grey-black		87	90	3
D. G. with medium-fine sand, water-bearing, sulphur odor	x	90	96	6
Clay, tight, gummy		96	98	2
D. G. WITH COURSE PARTICLES	x	98	140	42

NOTE: Well sealed to a depth of 102 feet to shut off sulphur laden water

TD: 140 feet  
 10 feet of blank casing on bottom of string

8. WELL CONSTRUCTION  
 Diameter 11 3/4 inches Total depth 140 feet  
 Casing record steel 6 5/8"  
 Weight per foot 11.7 Thickness .156  
 Diameter From To  
6 5/8 inches 1.2 feet 140 feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 102 feet  
 Gravel packed: Yes  No   
 Gravel packed from 102 feet to 140 feet  
 Perforations:  
 Type perforation Mill-slot, factory  
 Size perforation 3/32" x 3"  
 From 110 feet to 140 feet

Date started 4/25 1990  
 Date completed 4/26 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with clean water and gravel-packed. Finished well development with air. Blew 35 gpm from a depth of 110 feet			

9. WATER LEVEL  
 Static water level 9 feet below land surface  
 Flow 35 gpm G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

BAILER TEST

G.P.M.	Draw down	feet	hours

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H Pump Co. Contractor  
 Address Carson City, Nv 89701 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 23295  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
 Signed Joey Britts By driller performing actual drilling on site or contractor  
 Date 4/27/90