

OFFICE USE ONLY  
 Log No. 33245  
 Permit No. \_\_\_\_\_  
 Basin. 683 87  
 NOTICE OF INTENT NO. 13957

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Bill Calitri ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1755 E Plumb Ln # 103 270 Vermillion  
Reno, Nv 89502 Lot 27  
 2. LOCATION SE 1/4 SW 1/4 Sec 6 T 17 N/S R 21 E Storey County \_\_\_\_\_  
 PERMIT NO. 03-442-04 Highland Ranches  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	2
Blue & white volcanic rock		2	7	5
Brown volcanic rock w/trace brown clay		7	36	29
Brown, green white volcanic rock		36	75	39
Gray white volcanic rock		75	177	102
Gray white green volcanic rock		177	240	63
T.D. 240 ft				

8. 10" - 55" WELL CONSTRUCTION  
 Diameter 8 1/2 inches Total depth 240 feet  
 Casing record 6 5/8 inch  
 Weight per foot 10.78 Thickness .156  

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1</u> feet	<u>240</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 240 feet  
 Perforations:  
 Type perforation factory [double]  
 Size perforation 3/32 X 3  
 From 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4/27/90 19\_\_\_\_  
 Date completed 4/30/90 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Flow 20+ G.P.M. P.S.I. \_\_\_\_\_  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Address 625 Spice Islands Dr Suite L Sparks, NV 89431  
 Nevada contractor's license number issued by the State Contractor's Board 15291  
 Nevada contractor's driller's number issued by the Division of Water Resources 1132  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date 4/30/90 Roger M. Thrall