

OFFICE USE ONLY
 Log No. 35274
 Permit No. _____
 Basin 6-91

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 13743

PRINT OR TYPE ONLY

1. OWNER JERRY PONCIA ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 231 South Virginia Street 595 Riverdale Cir.
Reno, NV 89501 Verdi, NV 89439 lot 5 NWD
 2. LOCATION SW 1/4 N.W. 1/4 Sec. 8 T. 19N N/S R. 18 E Washoe County
 PERMIT NO. _____ 638-691-63 Riverdale Subdivision, Verdi Unit 1
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Decpen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill dirt		0	5	5
Smaller bolders with sand & clay		5	16	11
Bir bolders with brown clay		16	49	33
Gray clay		49	69	20
Black volcanic rock		69	153	84
Soft zone (app 3GPM)	X	153	156	3
Black volcanic rock		156	210	54
Soft zone (app 5GPM)	X	210	212	2
Black volcanic rock		212	263	51
Soft zone	X	263	265	2
Black volcanic rock		265	268	3
Gray volcanic rock		268	275	7

'90 APR 27 AM 11
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 275 feet

Casing record 275' steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>275</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement grout
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 275 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 195 feet to 215 feet
 From 255 feet to 275 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4-13-90, 19____
 Date completed 4-17-90, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 82 feet below land surface
 Flow 18 1/2 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
By driller performing actual drilling on site or contractor
 Date Apr 11 20, 1990