

OFFICE USE ONLY  
 Log No. 33275  
 Permit No. \_\_\_\_\_  
 Basin. 6-901

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 9218

PRINT OR TYPE ONLY

1. OWNER CHRISTENSEN CONSTRUCTION ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 1155 420 Leventina Canyon Road  
Verdi, NV 89439 Verdi, NV 89439  
 2. LOCATION SW 1/4 SW 1/4 Sec. 15 T. 19N N/S R. 18 E Washoe County  
 PERMIT NO. 038-671-o2 Belli Ranch  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil with gravels		0	3	3
Boulders, gravles with brown sandy clay		3	102	99
Soft brown sandy clay		102	145	43
Black clay		145	219	74
Soft zone (app 5 GPM)	X	219	221	2
Black to gray clay		221	265	5
Soft zone (app 6 GPM)	X	265	270	5
Black to gray clay		270	285	15

'90 MAY -7 P12:36  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Diameter 6 inches Total depth 285 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 285' steel casing installed.  
 Weight per foot \_\_\_\_\_ Thickness 156  
 \_\_\_\_\_  

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>285</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type cement grout seal  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 285 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From 220 feet to 240 feet  
 From 260 feet to 280 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4-26-90, 19\_\_\_\_  
 Date completed 4-27-90, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 161 feet below land surface  
 Flow 11 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc.  
Contractor  
 Address P.O. Box 12370, Reno, NV 89510  
Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada contractor's driller's number issued by the Division of Water Resources 908  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature]  
Driller performing actual drilling on site or contractor  
 Date 5-3-90

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours